

WL-TR-96-3067

**FLUOROIODIDE BLENDS AS
STREAMING AGENTS: SELECTION
CRITERIA AND CUP-BURNER RESULTS**



Robert E. Tapscott, Ted A. Moore
Stephanie R. Skaggs, Everett W. Heinonen

New Mexico Engineering Research Institute
The University of New Mexico
Albuquerque, New Mexico 87131-1376

JUNE 1995

FINAL REPORT FOR 3/95 -- 11/95

Approved for public release; distribution unlimited

Prepared for:

Wright Laboratories (WL/FIVCF)
139 Barnes Drive, Suite 2
Infrastructure Technology Section
Tyndall Air Force Base, Florida 32403-5323

and

Applied Research Associates, Inc.
P.O. Box 40128
Tyndall Air Force Base, Florida 32403-5323

**FLIGHT DYNAMICS DIRECTORATE
WRIGHT LABORATORY
AIR FORCE MATERIEL COMMAND
WRIGHT-PATTERSON AIR FORCE BASE, OH 45433-7562**

19960617 145

DTIC QUALITY INSPECTED 1

NOTICES

WHEN GOVERNMENT DRAWINGS, SPECIFICATIONS, OR OTHER DATA ARE USED FOR ANY PURPOSE OTHER THAN IN CONNECTION WITH A DEFINITE GOVERNMENT-RELATED PROCUREMENT, THE UNITED STATES GOVERNMENT INCURS NO RESPONSIBILITY OR ANY OBLIGATION WHATSOEVER. THE FACT THAT THE GOVERNMENT MAY HAVE FORMULATED OR IN ANY WAY SUPPLIED THE SAID DRAWINGS, SPECIFICATIONS, OR OTHER DATA, IS NOT TO BE REGARDED BY IMPLICATION, OR OTHERWISE IN ANY MANNER CONSTRUED, AS LICENSING THE HOLDER, OR ANY OTHER PERSON OR CORPORATION; OR AS CONVEYING ANY RIGHTS OR PERMISSION TO MANUFACTURE, USE, OR SELL ANY PATENTED INVENTION THAT MAY IN ANY WAY BE RELATED THERETO.

The Public Affairs Office (PA) has reviewed this report and it is releasable to the National Technical Information Service (NTIS). At NTIS, the report will be made available to the general public, including foreign nationals.

This technical report has been reviewed and is approved for publication.



CHARLES J. KIBERT
Project Officer

FOR THE COMMANDER:



RICHARD N. VICKERS
Chief, Infrastructure Technology Section



EDGAR F. ALEXANDER
Chief, Air Base Technology Branch

If your address has changed, if you wish to be removed from our mailing list, or if the addressee is no longer employed by your organization, please notify WL/FIVC, Tyndall AFB Florida 32403-5323, to help maintain a current mailing list.

Copies of this report should not be returned unless required by security considerations contractual obligations, or notice on a specific document.

REPORT DOCUMENTATION PAGE			Form Approved OMB No. 0704-0188	
Public reporting burden for this collection of information is estimated to average 1 hour per response, including the time for reviewing instructions, searching existing data sources, gathering and maintaining the data needed, and completing and reviewing the collection of information. Send comments regarding this burden estimate or any other aspect of this collection of information, including suggestions for reducing this burden, to Washington Headquarters Services, Directorate for Information Operations and Reports, 1215 Jefferson Davis Highway, Suite 1204, Arlington, VA 22202-4302, and to the Office of Management and Budget, Paperwork Reduction Project (0704-0188), Washington, DC 20503.				
1. AGENCY USE ONLY (Leave blank)	2. REPORT DATE June 1995	3. REPORT TYPE AND DATES COVERED FINAL 3/95--11/95		
4. TITLE AND SUBTITLE Fluoriodide Blends As Streaming Agents: Selection Criteria and Cup-Burner Results		5. FUNDING NUMBERS F 08635-93-C-0020 PE: 63716D PR: 2673 TA: 30 WU: 03		
6. AUTHOR(S) Ted A. Moore, Robert E. Tapscott, Stephanie R. Skaggs, Everett W. Heinonen				
7. PERFORMING ORGANIZATION NAME(S) AND ADDRESS(ES) New Mexico Engineering Research Institute University of New Mexico Albuquerque, New Mexico 87131-1376		8. PERFORMING ORGANIZATION REPORT NUMBER NMERI 1995/8/31790		
9. SPONSORING/MONITORING AGENCY NAME(S) AND ADDRESS(ES) Flight Dynamics Directorate Wright Laboratory Air Force Materiel Command Wright Patterson Air Force Base, Ohio 45433-77562		10. SPONSORING/MONITORING AGENCY REPORT NUMBER WL-TR-96-3067		
11. SUPPLEMENTARY NOTES Prepared for: Wright Laboratories (WL/FIVCF) Infrastructure Technology Section Tyndall Air Force Base, Florida 32403-5323				
12a. DISTRIBUTION/AVAILABILITY STATEMENT Approved for Public Release; Distribution is Unlimited			12b. DISTRIBUTION CODE	
13. ABSTRACT (Maximum 200 words) Fluoriodocarbons (FIC) -- highly effective, "second-generation" agents -- have been identified as replacements for halons, the production of which ended on 31 December 1993. In an attempt to improve the toxicological characteristics of FICs, to decrease agent cost, and to possibly improve performance as a streaming agent in military applications, blends of FICs with other chemicals are being investigated. This report describes the initial results of the blending work with trifluoriodomethane (CF ₃ I), the most promising FIC fire suppressant. Toxicities, likely regulatory regulations, and availability indicate that only hydrofluorocarbons (HFC) can be considered at this time for blending with CF ₃ I or other FICs. Seven HFCs (HFC-236fa, -227ea, -143a, -134a, -125, -23, and -4-3-10mee) were selected for initial investigation. Based on the toxicities of CF ₃ I and the proposed blending agents, the final blends should contain 40 percent or less by volume CF ₃ I in order for the cardiac sensitization No Observed Adverse Effect Level (NOAEL) value to be equal to that of Halon 1211. Cup-burner extinguishment concentrations at a 40 percent by volume CF ₃ I concentration ranged from slightly higher to significantly lower than those for pure CF ₃ I. Those agents identified as meeting the criteria for continuation in the program should be tested in laboratory- and field-scale streaming apparatuses.				
14. SUBJECT TERMS Fluoriodocarbons; FIC; Halon 1211; Halon replacement; Trifluoriodomethane; CF ₃ I; Streaming agent			15. NUMBER OF PAGES 56	
			16. PRICE CODE	
17. SECURITY CLASSIFICATION OF REPORT UNCLASSIFIED	18. SECURITY CLASSIFICATION OF THIS PAGE UNCLASSIFIED	19. SECURITY CLASSIFICATION OF ABSTRACT UNCLASSIFIED	20. LIMITATION OF ABSTRACT SAR	

TABLE OF CONTENTS

<u>Section</u>	<u>Page</u>
I INTRODUCTION.....	1
II RATIONALE.....	5
A. HIGHLY REGULATED COMPOUNDS	6
B. HALOCARBON FAMILIES WITH SUSPECT TOXICITIES.....	6
C. HYDROCHLOROFLUOROCARBONS	6
D. PERFLUOROCARBONS	6
E. HYDROFLUOROCARBONS.....	7
III PRELIMINARY SELECTION OF BLENDING AGENTS.....	8
A. RATIONALE.....	8
B. INITIAL SELECTION OF HYDROFLUOROCARBONS.....	8
C. ADDITIONAL COMMERCIALY AVAILABLE PRODUCTS	8
1. Hydrofluoroethers	8
2. HFC-4-3-10mee	11
3. HFC-356mcf	11
D. DOWNSELECTION OF HYDROFLUOROCARBONS.....	11
E. TOXICITY ASSESSMENT	12
IV CUP-BURNER EXTINGUISHMENT CONCENTRATIONS.....	15
A. CUP-BURNER TEST METHOD.....	15
1. Gaseous Agent Cup-Burner Test Method.....	15
2. Liquid Agent-Cylinder (Discharge) Cup-Burner Test Method.....	17
B. CUP-BURNER TEST RESULTS	17
C. DISCUSSION	29
D. SUMMARY	38
V CONCLUSIONS AND RECOMMENDATIONS.....	39
A. CONCLUSIONS.....	39
B. RECOMMENDATIONS	39
REFERENCES	40

LIST OF FIGURES

<u>Figure</u>	<u>Page</u>
1	Classical Cup-Burner Apparatus Configuration for Testing Gaseous Agents. 16
2	Revised Cup-Burner Apparatus Configuration for Testing Blends..... 18
3	Cup-Burner Extinguishment Concentrations for CF ₃ I and HFC-125 blends. 19
4	Cup-Burner Extinguishment Concentrations for CF ₃ I and HFC-134a blends. 19
5	Cup-Burner Extinguishment Concentrations for CF ₃ I and HFC-227ea Blends. 23
6	Cup-Burner Extinguishment Concentrations for CF ₃ I and HFC-236fa Blends. 28
7	Average Cup-Burner Extinguishment Concentrations for CF ₃ I and HFC-236fa Blends. 28
8	Blend Test #1: 21.2% CF ₃ I and 78.8% HFC-227ea Scan at Start of Test..... 35
9	Blend Test #1: 21.2% CF ₃ I and 78.8% HFC-227ea Scan Towards End of Test..... 35
10	Blend Test #2: 23.1% CF ₃ I and 76.9% HFC-236fa Scan at Start of Test. 36
11	Blend Test #2: 23.1% CF ₃ I and 76.9% HFC-236fa Scan Towards End of Test. 36
12	Blend Test #5: 41.5% CF ₃ I and 58.5% HFC-236fa Scan at Start of Test. 37
13	Blend Test #5: 41.5% CF ₃ I and 58.5% HFC-236fa Scan Towards End of Test. 37
14	Summary of Cup-Burner Extinguishment Concentrations for HFC and CF ₃ I Blends..... 38

LIST OF TABLES

<u>Table</u>	<u>Page</u>
1	PHYSICAL PROPERTIES OF HALON 1301, HALON 1211, AND CF ₃ I. 2
2	TOXICOLOGICAL PROPERTIES OF HALON 1211 AND CF ₃ I. 3
3	CARDIAC SENSITIZATION PREDICTIONS AND MEASUREMENTS FOR HALOCARBON BLENDS. 4
4	CRITERIA FOR BLENDING CHEMICAL. 5
5	ALL HYDROFLUOROCARBONS IN CGET CHEMICAL OPTIONS DATABASE. 9
6	COMMERCIALIZED HYDROFLUOROETHERS. 10
7	INITIAL DOWNSELECTION LIST. 13
8	CARDIAC SENSITIZATION VALUES FOR INITIAL DOWNSELECTION LIST. 13
9	PROPORTION OF BLENDING AGENTS FOR CF ₃ I MIXTURES. 14
10	CUP-BURNER DATA FOR CF ₃ I AND HFC-125a BLENDS. 20
11	CUP-BURNER DATA FOR CF ₃ I AND HFC-134a BLENDS. 21
12	CUP-BURNER DATA FOR CF ₃ I AND HFC-227ea BLENDS. 24
13	CUP-BURNER DATA FOR CF ₃ I AND HFC-236fa BLENDS. 25
14	SELECTED DATA FOR 68.9 PERCENT HFC-236fa AND 31.1 PERCENT CF ₃ I BLEND. 30
15	FTIR EXPERIMENTAL TEST RESULTS: CF ₃ I AND HFC-227ea BLENDS. 31
16	FTIR EXPERIMENTAL TEST RESULTS: CF ₃ I AND HFC-236fa BLENDS. 32

LIST OF ABBREVIATIONS

ACGIH	American Conference of Governmental Industrial Hygienists
AEL	Acceptable Exposure Limit
AFB	Air Force Base
ALC	Approximate Lethal Concentration
APT	Advanced Protection Technologies
ARA	Applied Research Associates
CAS	Chemical Abstract Services
CFC	chlorofluorocarbon
CGET	Center for Global Environmental Technologies
CNS	Central Nervous System
EPA	Environmental Protection Agency
FC	fluorocarbon (perfluorocarbon)
FIC	fluoriodocarbon
FTIR	Fourier Transform Infrared
GWP	Global Warming Potential
HBFC	hydrobromofluorocarbon
HCFC	hydrochlorofluorocarbon
HFC	hydrofluorocarbon
IUPAC	International Union of Pure and Applied Chemistry
LOAEL	Lowest Observed Adverse Effect Level
NMERI	New Mexico Engineering Research Institute
NOAEL	No Observed Adverse Effect Level
ODP	Ozone Depletion Potential
PFC	perfluorocarbon
SNAP	Significant New Alternatives Policy
U.S.	United States
USAF	United States Air Force
VOC	Volatile Organic Compound

FOREWARD

A. OBJECTIVE

The objective of the overall advanced agent program is to develop new, highly effective chemicals to replace Halon 1211 in military streaming applications. The portion of the work discussed in this document has, as an objective, the development of fluoriodocarbon (FIC) blends as Halon 1211 replacements for streaming agents. This report documents initial work in that area.

B. BACKGROUND

The production of halons, used for fire and explosion protection, ended on 31 December 1993 in developed nations. Among the candidates being developed to replace halons are the FICs, highly effective, "second-generation" agents. In an attempt to improve the toxicological characteristics of FICs, to decrease agent cost, and to possibly improve performance as a streaming agent, blends of FICs with other chemicals are being investigated under a much larger advanced streaming agent development program. This report describes the initial results of the blending work with trifluoriodomethane (CF_3I), the most promising FIC fire suppressant.

C. SCOPE

Work to develop advanced halon replacements was initiated in September 1993 under the Advanced Streaming Agent Testing Program. The objective of this program, which is now being continued under the Advanced Agent Program, is to develop new advanced chemical replacements for Halon 1211 in streaming applications. Fluoriodocarbon blends, the subject of this report, is one element of the Advanced Agent Program.

D. RESULTS

Consideration of toxicities, likely regulatory regulations, and availability indicated that only hydrofluorocarbons (HFC) can be considered for blending with CF_3I or other FICs (at the time that this study was performed). Forty-four (44) HFCs were selected from the CGET CHEMICAL OPTIONS Database to obtain an initial broad list of compounds. Two recently-

announced HFCs were also added to the list. From this broad list, seven HFCs (HFC-236fa, -227ea, -143a, -134a, -125, -23, and -4-3-10mee) were selected for initial investigation. Based on the toxicities of CF₃I and the proposed blending agents, it is estimated that less than 40 percent by volume CF₃I must be contained in a mixture in order for the cardiac sensitization No Observed Adverse Effect Level (NOAEL) value for the blend to be equal to that of Halon 1211.

Cup-burner extinguishment concentrations were obtained for the pure agents and blends. Test descriptions and results are presented.

E. CONCLUSIONS

Seven HFC chemicals (HFC-236fa, -227ea, -143a, -134a, -125, -23, and -4-3-10mee) have been identified that meet toxicity, regulatory, and availability requirements for inclusions as blending agents with CF₃I. For the five agents with known cardiac sensitization NOAEL, no more than 40 percent CF₃I may be contained in a blend in order to have the same cardiac sensitization NOAEL as that of Halon 1211. Fire suppression effectiveness testing using the cup-burner method gave extinguishment concentrations for four blended agents containing 40 percent CF₃I; these concentrations ranged from slightly higher than that of pure CF₃I to significantly lower (for blends with HFC-227ea). The reason for unexpectedly low extinguishment concentrations for some blends cannot be explained at this time. Separation of the components in the test cylinder was indicated to be negligible through Fast Fourier Transform Infrared (FTIR) spectroscopy analysis at different times during agent discharge.

F. RECOMMENDATIONS

Those agents identified in this effort as meeting the requirements for blending with CF₃I should be tested in laboratory- and medium-scale apparatuses to determine their performance as a streaming agent. Cardiac sensitization NOAEL and Lowest Observed Adverse Effect Level (LOAEL) values should be obtained for CF₃I blends identified in this phase of the project.

PREFACE

This report was prepared by the Center for Global Environmental Technologies (CGET), New Mexico Engineering Research Institute (NMERI), The University of New Mexico, Albuquerque, New Mexico, for the Infrastructure Technology Section of Wright Laboratory (WL/FIVCF), Tyndall Air Force Base, Florida, and Applied Research Associates (ARA), Inc., Tyndall Air Force Base, Florida 32403-5323, under Contract S-5000.7, NMERI Number 8-31790. This document provides a review of fluoroiodocarbon blends as potential halon streaming agents.

The Start Date for the overall Advanced Streaming Agent Program was 27 September 1993, and the End Date was 31 December 1994. The program segment on fluoroiodocarbon blends, the subject of this report, was initiated in October 1994. The WL/FIVCF Project Officer was Charles J. Kibert, the ARA Project Officer was Michael A. Rochefort, and the NMERI Principal Investigator was Stephanie R. Skaggs.

NMERI 1995/8/31790

SECTION I

INTRODUCTION

Halon production ceased at the end of December 1993. A number of candidate replacement agents have been announced by industry for commercialization, and additional chemicals are under consideration. Most of the announced agents are "first-generation" agents — hydrochlorofluorocarbons (HCFC), hydrofluorocarbons (HFC), perfluorocarbons (PFC or FC), and hydrobromofluorocarbons (HBFC). All of the first-generation candidates, however, have one or more drawbacks in terms of effectiveness, global environmental impact, or regulatory acceptance. Consequently, the search for candidates that are effective but have minimal global environmental impacts has continued.

"Second-generation" halon replacements are designed specifically to avoid the effectiveness and environmental tradeoffs of first-generation agents. Second-generation agents are highly effective fire extinguishants, but have zero or near-zero Ozone Depletion Potential (ODP) and Global Warming Potential (GWP). The most promising near-term second-generation candidate identified to date is trifluoroiodomethane (CF_3I).

Despite the promise of CF_3I as a halon replacement, a number of potentially show-stopping questions remained unanswered in early 1993. Thus, in May 1993, a coordinated ad hoc working group was formed to expedite the development of CF_3I . Members of the CF_3I Ad Hoc Working Group included representatives from the United States Air Force (USAF), U.S. Navy, U.S. Army, North Slope Halon Task Group, Pacific Scientific, and West Florida Ordnance. Over the next 18 months, studies were performed to address issues related to fire suppression and explosion prevention effectiveness, initial acute toxicology, global environmental impacts, manufacturability, chemical stability, and materials compatibility. Results and conclusions on the work accomplished by the CF_3I Ad Hoc Working Group are compiled in Reference 1.

Throughout the development of CF_3I , the candidate had been emphasized as a Halon 1301 replacement for total-flood applications, because the physical and chemical characteristics

are more similar to those of Halon 1301 than to the characteristics of Halon 1211, which is used in streaming applications (Table 1). However, initial field-scale experiments with CF₃I at Tyndall Air Force Base revealed that the chemical also demonstrates superior firefighting capabilities in streaming scenarios. Consequently, CF₃I has received significant attention by the military and industry as a streaming agent candidate.

TABLE 1. PHYSICAL PROPERTIES OF HALON 1301, HALON 1211, AND CF₃I.^a

Physical Property	Halon 1301	Halon 1211	CF ₃ I
CAS No.	75-63-8	353-59-3	2314-97-8
Molecular weight, g/mole	148.91	165.37	195.91
Physical state at 20 °C	Gas	Gas	Gas
Melting point, °C	-168	-160.5	-110 (est.)
Boiling point, °C	-57.75	-3.4	-22.5
Liquid density at 20-25 °C, g/mL	1.54	1.83	2.096
Vapor pressure, psia at 25 °C	234.8	40.0	78.4
Heat of vaporization, kJ/kg	118.8	132.6	112.3
Liquid heat capacity, J/kg	870	775	592 (est.)
Vapor heat capacity, J/kg	469	452	361.8
Critical pressure, psia	574.6	610.0	586 (est.)
Critical temperature, °C	67	153.8	122 (est.)
Critical density, g/mL	0.745	0.713	0.87 (est.)

^aValues from the CGET CHEMICAL OPTIONS Database.

The toxicological properties of Halon 1211 and CF₃I are provided in Table 2. Cardiac sensitization is the toxicological property emphasized since it is believed to be the effect that occurs at the lowest concentration when animals or humans are exposed to halocarbons (Reference 2). Some feel that since the cardiac sensitization threshold for CF₃I is lower than that of Halon 1211, a sufficient safety margin would not be provided if CF₃I were to be considered as a streaming agent. This conservative view may not be appropriate since studies on firefighter

TABLE 2. TOXICOLOGICAL PROPERTIES OF HALON 1211 AND CF₃I.

Toxicity Parameter	Halon 1211	CF ₃ I
Lethal concentration LC ₅₀ , rat, 15-min	^a 20 %	^b 27.4 %
Acute exposure, rat	^c 5.8 %, 12 min: Slight muscle tremors	^d 12 %, 15 min: Salivation, audible breathing
Cardiac sensitization, dog, 5-min, epinephrine challenge	^e NOAEL = 0.5 % LOAEL = 1.0 %	^f NOAEL = 0.2 % LOAEL = 0.4 %

^aReference 3.^bReference 4.^cReference 5.^dReference 6.^eReference 5; criteria for cardiac sensitization was ventricular tachycardia or fibrillation. Ventricular ectopic beats were observed in dogs exposed at 5 %.^fReference 7; criteria for cardiac sensitization was multifocal ventricular ectopic beats or fibrillation.

exposure have shown that personnel are unlikely to be exposed to concentrations greater than 1000 ppm (0.1 percent) for streaming agents with an effectiveness similar to that of Halon 1211. Nonetheless, an effort is underway to blend CF₃I (and possibly other fluoroidocarbons [FIC]) with low toxicity agents in an attempt to improve the toxicological characteristics.

The goal in searching for CF₃I blends is to find a blend or blends with acceptable fire extinguishing efficiency and one that also has cardiac sensitization No Observed Adverse Effect Levels (NOAEL) equal to or greater than Halon 1211 (0.5 percent). The strategy is to mix CF₃I with blending agents that have much higher cardiac sensitization NOAEL relative to CF₃I. In theory, a blend of CF₃I with a "non-toxic" blending agent would yield a mixture with a cardiac sensitization NOAEL greater than CF₃I itself (i.e., a higher concentration would be needed to elicit a cardiac sensitization response). A common method for predicting the toxicity of a mixture is adapted from the American Conference of Governmental Industrial Hygienists

(ACGIH) (Reference 8). According to this method, the toxicity index of a binary mixture is calculated according to Equation (1).

$$1/T = C_a/T_a + C_b/T_b \quad (1)$$

where T is the toxicity index of the blend; C_a and T_a are the concentration and toxicity index of component a; C_b and T_b are the concentration and toxicity index of component b, and

$$C_a + C_b = 1 \quad (2)$$

Evidence in other halocarbon blends, however, suggests that this relationship may not hold true in all cases. Predicting the cardiac sensitization NOAEL of a mixture from the cardiac sensitization NOAEL values for the individual blend components has not always proven a reliable indicator for other halocarbon blends. For example, the predicted and measured cardiac sensitization NOAEL values for three halocarbon blends are listed in Table 3. One can see that the correlation between the predicted and measured NOAEL values is not good, at least in the case of HCFC Blend A.

TABLE 3. CARDIAC SENSITIZATION PREDICTIONS AND MEASUREMENTS FOR HALOCARBON BLENDS.

Halocarbon Blend		Predicted Cardiac Sensitization NOAEL, %	Measured Cardiac Sensitization NOAEL, %
HCFC Blend A	82 % HCFC-22	2.1	^a 10
	9.5 % HCFC-124		
	4.75 % HCFC-123		
	3.75 % limonene		
23/125	36.5 % HFC 23	11	^b < 10
	63.5 % HFC 125		
R-502	51 % CFC-115	4.4	^c 5
	49 % HCFC-22		

^aReference 9.

^bReference 10; 10 % was the only concentration tested. One dog experienced ventricular fibrillation and death at 10%.

^cReference 11.

SECTION II

RATIONALE

Blending agents for use in USAF streaming applications must meet the criteria shown in Table 4, which are listed approximately in the order of importance. Note that fewer criteria are needed for a blending agent than for an active firefighting component. In particular, although fire extinguishing ability is not a major factor, toxicity is considered critical.

TABLE 4. CRITERIA FOR BLENDING CHEMICAL.

Property	Criteria
Toxicity	A blending agent must have a very low toxicity if the final blend is to have toxicity characteristics similar to those of Halon 1211. In particular, significant toxicological studies must have been performed, must be underway, or must be planned.
Environmental	A blending agent candidate must not now be regulated nor should it be regulated in the "near" future. The Ozone Depletion Potential (ODP) must be essentially zero.
Availability	Any material must be available in sufficient bulk for testing and manufacture must, at least, be planned.
Flammability	The material must have a very low flammability; however, marginally flammable materials might be acceptable as blending agents.
Boiling Point	The boiling point must be sufficiently high to allow use of the blending chemical without extensive equipment modification.
Materials Compatibility	The blending agent must be compatible with fire extinguisher components and with other materials with which it comes into contact.

Taking the above variables and the present state of knowledge into account, halocarbons are the most likely blending agents. There are now few, if any, other types of available blending materials that have the potential of being low in both flammability and toxicity, and have the required availability. Each type of halocarbon is discussed below.

A. HIGHLY REGULATED COMPOUNDS

Chlorofluorocarbons (CFC), hydrobromofluorocarbons (HBFC), carbon tetrachloride, and methyl chloroform can be eliminated from consideration since these chemicals are now or soon will be banned. Carbon tetrachloride cannot be used for other reasons as well.

B. HALOCARBON FAMILIES WITH SUSPECT TOXICITIES

Based on known toxicities of FICs, it is obvious that they should not be used to decrease the toxicity of blends containing other FICs. Alkenes are also unlikely to have a sufficiently low toxicity to meet the blending agent requirements. Nonfluorinated chlorocarbons and bromocarbons are often toxic and, in some cases, are regulated. Thus iodides, alkenes, and nonfluorinated chlorocarbons and bromocarbons are not recommended for blending.

C. HYDROCHLOROFLUOROCARBONS

HCFCs have exceptionally good properties for use as blending agents. A large number of these agents are known, the toxicities are often relatively low, and they are likely to blend well with iodides. However, HCFCs will be phased out of production in the future due to their non-zero Ozone Depletion Potential (ODP). Therefore, HCFCs are not recommended as blending agents.

D. PERFLUOROCARBONS

PFCs are fully fluorinated compounds (unlike CFCs, HCFCs, or HFCs) and have several attractive features. They are nonflammable, have very low toxicity, are exempt from federal Volatile Organic Compound (VOC) regulations, and do not contribute to stratospheric ozone depletion. However, under the Significant New Alternatives Policy (SNAP) program, the Environmental Protection Agency (EPA) has applied caution to the use of PFCs. The environmental characteristics of concern are their high GWP (approximately 5000 times that of carbon dioxide) and their long atmospheric lifetimes (about 3000 years). Although the actual contributions to global warming depend upon the quantities emitted, the long lifetimes make the warming effects of PFCs virtually irreversible. EPA allows the use of PFCs in fire

extinguishants only for special applications where no other substitute would meet performance or safety requirements. Consequently, PFCs are not recommended for blending.

E. HYDROFLUOROCARBONS

HFCs are receiving increased prominence as replacements for ozone-depleting substances for three reasons: (1) they are usually volatile and many have low toxicities; (2) because they are not ozone depleting (as apposed to the HCFCs) and, because they have lower atmospheric lifetimes than PFCs, they are likely to receive less regulatory action than HCFCs or PFCs; and (3) they have properties similar to those of halocarbons that have been used in the past. This does not, however, mean that HFCs are not receiving attention from environmental organizations. A recent study by the National Institute of Public Health and Environmental Protection, The Netherlands, has projected a significant increase in greenhouse gas emissions as a result of the use of HFCs to replace CFCs and HCFCs (Reference 12). Moreover, the 1994 report of the UNEP (United Nations Environment Programme) Halon Technical Options Committee (HTOC) states that "...several governments have already restricted or banned the use of HFCs and PFCs" (Reference 13). Nevertheless, HFCs are the most promising halocarbons for use as blending agents with FICs.

SECTION III

PRELIMINARY SELECTION OF BLENDING AGENTS

A. RATIONALE

Consideration of toxicities, likely regulatory restrictions, and availability indicates that, at this time, only HFCs can be considered for blending with CF_3I or other FICs. HCFCs are being restricted in Europe, particularly for fire protection, and this greatly decreases their applicability in operations that could require application in overseas operations. Moreover, limitations on HCFCs are likely to spread to the U.S. (in fact, regulations against HCFCs in fire extinguishers for domestic use are already in place). Restrictions on PFCs are rapidly increasing in the U.S.

B. INITIAL SELECTION OF HYDROFLUOROCARBONS

The CGET CHEMICAL OPTIONS Database of 907 compounds was used to select an initial broad list of 44 HFCs (Table 5).

C. ADDITIONAL COMMERCIALY AVAILABLE PRODUCTS

1. Hydrofluoroethers

Recently, three new fluorinated materials were announced without details on the specific compounds (Reference 14). The compositions of two of these materials have now been released and the properties are given in Table 6 (Reference 15). The composition of a third material, Liquid C, has not been reported. The reported chemicals, which are the partially fluorinated ethers methyl perfluorobutyl ether ($\text{C}_4\text{F}_9\text{OCH}_3$) and ethyl perfluorobutyl ether ($\text{C}_4\text{F}_9\text{OC}_2\text{H}_5$), appear to be exceptionally attractive. With a zero ODP and a lifetime lower than that of either the HFCs or the PFCs, they are unlikely to suffer from regulatory restrictions. Additionally, they are not VOCs and the toxicity appears to be very low. Because the formulations of these compounds were released after the work on this project was completed, it was not possible to include an assessment in this initial work; however, hydrofluoroethers appear to be very attractive as blending agents and should be considered for use in the future.

TABLE 5. ALL HYDROFLUOROCARBONS IN CGET CHEMICAL OPTIONS DATABASE.

Halocarbon No.	Formula	IUPAC Name	CAS No.	BP, °C
HFC-C354	-CF ₂ CF ₂ CH ₂ CH ₂ -	1,1,2,2-Tetrafluorocyclobutane	374-12-9	50
HFC-C234	-CF ₂ CF ₂ CH ₂ -	1,1,2,2-Tetrafluorocyclopropane	3899-71-6	--
HFC-392	CH ₃ CF ₂ CH ₂ CH ₃	2,2-Difluorobutane	353-81-1	31
HFC-374	CH ₃ CF ₂ CF ₂ CH ₃	2,2,3,3-Tetrafluorobutane	471-74-9	17
HFC-365	CF ₃ CH ₂ CF ₂ CH ₃	1,1,1,3,3-Pentafluorobutane	406-58-6	--
HFC-281ea	CH ₃ CHFCH ₃	2-Fluoropropane	420-26-8	-9.39
HFC-281fa	CH ₃ CH ₂ CH ₂ F	1-Fluoropropane	460-13-9	-2.5
HFC-272ca	CH ₃ CF ₂ CH ₃	2,2-Difluoropropane	420-45-1	-0.1
HFC-272fb	CHF ₂ CH ₂ CH ₃	1,1-Difluoropropane	430-61-5	8
HFC-272fa	CH ₂ FCH ₂ CH ₂ F	1,3-Difluoropropane	462-39-5	41.6
HFC-272ea	CH ₂ FCHFCH ₃	1,2-Difluoropropane	62126-90-3	--
HFC-263fa	CHF ₂ CH ₂ CH ₂ F	1,1,3-Trifluoropropane	24270-67-5	--
HFC-263fb	CH ₃ CH ₂ CF ₃	1,1,1-Trifluoropropane	421-07-8	18
HFC-263eb	CHF ₂ CHFCH ₃	1,1,2-Trifluoropropane	66794-35-2	--
HFC-263ea	CH ₂ FCHFCH ₂ F	1,2,3-Trifluoropropane	66794-36-3	--
HFC-263ca	CH ₂ FCF ₂ CH ₃	1,2,2-Trifluoropropane	811-94-9	--
HFC-254ea	CHF ₂ CHFCH ₂ F	1,1,2,3-Tetrafluoropropane	24270-68-6	--
HFC-254cb	CHF ₂ CF ₂ CH ₃	1,1,2,2-Tetrafluoropropane	40723-63-5	--
HFC-254eb	CF ₃ CHFCH ₃	1,1,1,2-Tetrafluoropropane	421-48-7	--
HFC-254fb	CH ₂ FCH ₂ CF ₃	1,1,1,3-Tetrafluoropropane	460-36-6	29.4
HFC-254fa	CHF ₂ CH ₂ CHF ₂	1,1,3,3-Tetrafluoropropane	66794-30-7	--
HFC-254ca	CH ₂ FCF ₂ CH ₂ F	1,2,2,3-Tetrafluoropropane	813-75-2	--
HFC-245cb	CF ₃ CF ₂ CH ₃	1,1,1,2,2-Pentafluoropropane	1814-88-6	-17.72
HFC-245ea	CHF ₂ CHFCHF ₂	1,1,2,3,3-Pentafluoropropane	24270-66-4	--
HFC-245eb	CF ₃ CHFCH ₂ F	1,1,1,2,3-Pentafluoropropane	431-31-2	--
HFC-245fa	CF ₃ CH ₂ CF ₂ H	1,1,1,3,3-Pentafluoropropane	460-73-1	14
HFC-245ca	CHF ₂ CF ₂ CH ₂ F	1,1,2,2,3-Pentafluoropropane	679-86-7	--
HFC-236ea	CF ₃ CHFCHF ₂	1,1,1,2,3,3-Hexafluoropropane	431-63-0	6
HFC-236cb	CH ₂ FCF ₂ CF ₃	1,1,1,2,2,3-Hexafluoropropane	677-56-5	1.2
HFC-236ca	CHF ₂ CF ₂ CHF ₂	1,1,2,2,3,3-Hexafluoropropane	680-00-2	10

TABLE 5. ALL HYDROFLUOROCARBONS IN CGET CHEMICAL OPTIONS DATABASE (CONCLUDED).

Halocarbon No.	Formula	IUPAC Name	CAS No.	BP, °C
HFC-236fa	CF ₃ CH ₂ CF ₃	1,1,1,3,3,3-Hexafluoropropane	690-39-1	-1.5
HFC-227ca	CHF ₂ CF ₂ CF ₃	1,1,1,2,2,3,3-Heptafluoropropane	2252-84-8	-17
HFC-227ea	CF ₃ CHFCF ₃	1,1,1,2,3,3,3-Heptafluoropropane	431-89-0	19
HFC-161	CH ₃ CH ₂ F	Fluoroethane	353-36-6	-37.7
HFC-152	CH ₂ FCH ₂ F	1,2-Difluoroethane	624-72-6	30.67
HFC-152a	CH ₃ CHF ₂	1,1-Difluoroethane	75-37-6	-24.7
HFC-143a	CH ₃ CF ₃	1,1,1-Trifluoroethane	420-46-2	-47.61
HFC-143	CH ₂ FCHF ₂	1,1,2-Trifluoroethane	430-66-0	5
HFC-134	CHF ₂ CHF ₂	1,1,2,2-Tetrafluoroethane	359-35-3	-19.72
HFC-134a	CH ₂ FCF ₃	1,1,1,2-Tetrafluoroethane	811-97-2	-26.5
HFC-125	CHF ₂ CF ₃	Pentafluoroethane	354-33-6	-48.5
HFC-41	CH ₃ F	Fluoromethane	593-53-3	-78.41
HFC-32	CH ₂ F ₂	Difluoromethane	75-10-5	-51.6
HFC-23	CHF ₃	Trifluoromethane	75-46-7	-82.03

TABLE 6. COMMERCIALIZED HYDROFLUOROETHERS.

Property	C ₄ F ₉ OCH ₃	C ₄ F ₉ OC ₂ H ₅
Boiling point, °C	60	73
Melting point, °C	-135	-117
Flash point, °C	None	None
Flammability limits	None	None
Solubility of water at 25°C, ppm	95	92
Solubility in water at 25°C, ppm	<10	<10
Liquid density at 23°C, g/mL	1.50	1.43
Viscosity at 23°C, cp	0.4	0.4
Surface tension at 23°C, dynes/cm	13.6	13.6
Heat of vaporization, 23°C, cal/g	30	30
Specific heat, cal/g °C	0.28	0.29
Atmospheric lifetime, years	5.5	1.2
ALC	>10%	>5%

2. HFC-4-3-10mee

HFC-4-3-10mee (1,1,1,2,2,3,4,5,5,5-decafluoropentane, $\text{CF}_3\text{CHFCHFCF}_2\text{CF}_3$, named as HFC-43-10mee by the manufacturer) is a recent product announced by DuPont (Reference 16). The partially fluorinated pentane has a boiling point of 54 °C. The Approximate Lethal Concentration (ALC) is 10,000 ppm; the Acceptable Exposure Limit (AEL) (which is being reviewed) is 400 ppm. Other toxicity parameters look good. In particular, both the Ames and the rat micronucleus tests are negative. Although the compound is reported to have no cardiac sensitization, the limit of the cardiac sensitization testing has not been reported. The compound shows no eye or skin irritation, but does exhibit some Central Nervous System (CNS) effects.

3. HFC-356mcf

HFC-356mcf (1,1,1,2,2,4-hexafluorobutane, $\text{CF}_3\text{CF}_2\text{CH}_2\text{CH}_2\text{F}$) is a partially fluorinated butane manufactured by AlliedSignal. Although HFC-356mcf was first announced as a product on 24 October 1994, considerable information is available (Reference 17). The HFC will be commercialized in 1996. As a whole, the toxicity looks promising. Neither adverse reaction nor irritation has been found in acute dermal testing, and no cardiac sensitization has been observed at 2 percent. One potential problem rests with the human lymphocyte studies, which show positive activity but only at very high concentrations. This potential problem is expected to be resolved in a subchronic study. As this report was being written, AlliedSignal announced a suspension of the development of HFC-356mcf, at least for cleaning applications (Reference 18).

D. DOWNSELECTION OF HYDROFLUOROCARBONS

Any option to halons must be approved under the EPA's SNAP program, which implements Section 612 of the amended Clean Air Act of 1990. The plan for the SNAP program and an initial list of decisions on acceptable and unacceptable halon substitutes were promulgated on 18 March 1994 (Reference 19). This plan was prepared from an EPA background document for halon replacements and alternatives (Reference 20). Additional lists or proposed lists of acceptability decisions have been published (References 21-25). Substances

prohibited, acceptable only under certain conditions or for certain uses, or removed from a list of prohibited or acceptable substitutes are subject to public comment. Other substances for which there are no limitations are listed as acceptable with no public comment required. SNAP approval is required not only for pure materials but also for blends (and, by default, blend components).

Based on available toxicity information (or the promise that toxicity information will soon be available), on physical properties, and on availability, the chemicals in Table 7 were selected for initial investigations. This list contains one chemical, HFC-4-3-10mee, which was not in the initial broad list, but which was added later following announcement by the manufacturer. The SNAP assessment documents cited above were carefully reviewed to obtain regulatory environmental and toxicological assessments during this process. This list will likely change as further information is collected and reviewed. In addition, several of these materials, such as HFC-23, are likely to be too gaseous as blending chemicals for streaming agents and have not been emphasized as primary blend components.

E. TOXICITY ASSESSMENT

Table 8 presents the cardiac sensitization NOAEL values for the initial downselection list of chemicals in Table 7. Based on the method described earlier for predicting toxicity of mixtures, Equations (1) and (2) were used to estimate the HFC volume percentage needed to yielded a CF_3I mixture having a cardiac sensitization NOAEL equal to that of Halon 1211 (0.5 percent). The proportion of HFC for the mixture is listed in Table 9. As seen in this table, even for HFC-23, which has the highest cardiac sensitization NOAEL of all the blending agents, less than 40 mole percent CF_3I can be contained in a mixture in order for the estimated cardiac sensitization value for the blend to be equal to that of Halon 1211. Accordingly, future testing should focus on blends that have less than 40 percent CF_3I .

TABLE 7. INITIAL DOWNSELECTION LIST.

Halocarbon No.	Formula	IUPAC Name	CAS No.	BP, °C
HFC-236fa	CF ₃ CH ₂ CF ₃	1,1,1,3,3,3-Hexafluoropropane	690-39-1	-1.5
HFC-227ea	CF ₃ CHF ₂ CF ₃	1,1,1,2,3,3,3-Heptafluoropropane	431-89-0	19
HFC-143a	CH ₃ CF ₃	1,1,1-Trifluoroethane	420-46-2	-47.61
HFC-134a	CH ₂ FCF ₃	1,1,1,2-Tetrafluoroethane	811-97-2	-26.5
HFC-125	CHF ₂ CF ₃	Pentafluoroethane	354-33-6	-48.5
HFC-23	CHF ₃	Trifluoromethane	75-46-7	-82.03
HFC-43-10mee	CF ₃ CHFCHFCF ₂ CF ₃	1,1,1,2,2,3,4,5,5,5-Decafluoropentane	142347-08-8	54

TABLE 8. CARDIAC SENSITIZATION VALUES FOR INITIAL DOWNSELECTION LIST.

Halocarbon No.	Formula	Cardiac Sensitization NOAEL, %	Cardiac Sensitization LOAEL, %
HFC-23	CHF ₃	^a 50	^a >50
HFC-236fa	CF ₃ CH ₂ CF ₃	^b 10	^b 15
HFC-227ea	CF ₃ CHF ₂ CF ₃	9	10.5
HFC-125	CHF ₂ CF ₃	^a 7.5	^a 10
HFC-134a	CH ₂ FCF ₃	^c 4	^c 8
HFC-143a	CH ₃ CF ₃	^d 4	^d 8
HFC-4-3-10mee	CF ₃ CHFCHFCF ₂ CF ₃	Unknown	Unknown

^aReference 9^bReference 26^cReference 20^dReference 19

TABLE 9. PROPORTION OF BLENDING AGENTS FOR CF₃I MIXTURES.

Blending Agent	Blending Agent Cardiac NOAEL, %	Minimum Percentage of Blending Agent ^a	Maximum Percentage CF ₃ I, vol % ^a
HFC-23	50	60.2	39.8
HFC-236fa	10	61.2	38.8
HFC-227ea	9	61.4	38.6
HFC-125	7.5	61.6	38.4
HFC-134a	4	63.2	36.8
HFC-143a	4	63.2	36.8

^aLimiting amounts to obtain a NOAEL equal to or greater than that of Halon 1301 (0.5%).

SECTION IV

CUP-BURNER EXTINGUISHMENT CONCENTRATIONS

A. CUP-BURNER TEST METHOD

One of the most widely used apparatuses for determining the fire extinguishment concentration of Halon 1301 and 1211 replacements is the cup burner. Originally developed by Imperial Chemical Industries (ICI) in 1970 and refined in 1973, the cup burner is the standard flame extinguishment test technique accepted by the NFPA. The cup-burner apparatus was developed to measure the vapor phase performance of a chemical as a fire suppressant. Volumetric air and agent flow rates are used to calculate the molar percent concentration of agent required for flame extinguishment. Different techniques and equipment setups are required for testing gaseous, liquid, and "highly-volatile" liquid agents (Reference 27).^{*} The cup-burner apparatus consists of a glass chimney containing a small glass flame cup filled with a liquid fuel or containing a central burner for a gaseous fuel. Measured amounts of extinguishing agent and air enter the bottom of the chimney, are mixed, and allowed to pass by the ignited fuel. The amount of extinguishing agent is increased until the flame is extinguished, and the percent (molar, gas volume) concentration of agent is calculated. This calculated value is called the cup-burner extinguishment concentration.

1. Gaseous Agent Cup-Burner Test Method

Under previous USAF contracts, NMERI developed and refined a reduced-scale cup burner and several test methods. A different test method is used depending upon the characteristics of the agent being tested. The classical gaseous agent cup-burner test setup monitors the gaseous flow rate of the agent, or agents when testing blends, using a flow rotameter and a soap film bubble meter (Figure 1). The agents are blended in the gas phase in the cup-burner mixing chamber. The classical method was one method used to determine the cup-burner extinguishment concentrations of HFC-125, -134a, -227ea, and -236fa blended with CF₃I.

^{*} Moore, J. P., Moore, T. A., Salgado, D. P., and Tapscott, R. E., "Halon Alternatives Extinguishment Testing," International Conference on CFC and Halon Alternatives, Washington, DC, October 10-11, 1989.




Figure 1. Classical Cup-Burner Apparatus Configuration for Testing Gaseous Agents.

2. Liquid Agent-Cylinder (Discharge) Cup-Burner Test Method

Recently, a unique test method was developed based upon a discharge cylinder, needle valve, and electronic scale with computer data acquisition (Figure 2). Liquid compounds and those with boiling points near room temperature are usually tested using this liquid agent-cylinder (discharge) cup-burner method. The average results from five tests are used to determine the extinguishing concentration of the compound being tested. This method was also used to develop extinguishment concentrations for the CF_3I and HFC blends. In this method the CF_3I and the particular HFC compound were mixed in the discharge cylinder at various (pre-determined) weight percentages. Testing was then performed to determine the volume percent extinguishment concentration of the blend.

B. CUP-BURNER TEST RESULTS

Several blends of CF_3I and HFCs were tested using the NMERI 5/8-scale cup-burner test methods. The liquid agent-cylinder (discharge) method (Figure 2) and the gaseous agent method (Figure 1) were both used. Cup-burner tests were also performed at the Infrastructure Technology Section of Tyndall AFB, Florida, by Applied Research Associates, Inc., personnel, using their gaseous agent method. These unpublished Tyndall ARA data were originally based upon a volume percent blend ratio; however, for the discussion in this section, the ARA data were converted to a weight percent blend ratio. Over 200 cup-burner tests were performed with various blends of CF_3I and HFC-125, -134a, -227ea, and -236fa. The NMERI cup-burner test results for the CF_3I blends are shown in Tables 10 through 13.

Figure 3 and Table 10 show the cup-burner results for CF_3I blended with HFC-125 using the revised cup-burner test setup. The test data indicate that with 40 percent by weight CF_3I and greater in the blend, only a slight decrease in extinguishment performance from that of pure CF_3I would be experienced.

Figure 4 and Table 11 show the cup-burner results for CF_3I blended with HFC-134a using the discharge cup-burner test setup. An exponential curve fit to the Tyndall ARA data is also shown. The difference between the Tyndall ARA and the NMERI results is discussed further on in this section.




Figure 2. Revised Cup-Burner Apparatus Configuration for Testing Blends.




Figure 3. Cup-Burner Extinguishment Concentrations for CF_3I and HFC-125 Blends.




Figure 4. Cup-Burner Extinguishment Concentrations for CF_3I and HFC-134a Blends.

TABLE 10. CUP-BURNER DATA FOR CF₃I AND HFC-125 BLENDS.

Blend HFC-125/CF ₃ I, %	Test No.	Wt. % CF ₃ I	Ext. Conc., Vol. %	Ave Ext. Conc., Vol. %	Standard Deviation	% Error
100% HFC-125	NMERI Value	0	9.4	9.4		
100% HFC-125	1	0.0	9.5	9.1	0.3	3.8
	2	0.0	8.8			
	3	0.0	8.7			
	4	0.0	9.2			
	5	0.0	9.3			
88.5/11.5	1	11.5	6.4	6.0	0.6	9.2
	2	11.5	5.9			
	3	11.5	6.3			
	4	11.5	6.5			
	5	11.5	5.1			
82.4/17.6	1	17.6	6.9	7.4	0.3	4.7
	2	17.6	7.5			
	3	17.6	7.3			
	4	17.6	7.8			
	5	17.6	7.3			
80.6/19.4	1	19.4	6.4	6.6	0.2	3.1
	2	19.4	6.4			
	3	19.4	6.7			
	4	19.4	6.9			
	5	19.4	6.7			
75.3/24.7	1	24.7	5.2	5.8	0.5	7.9
	2	24.7	5.8			
	3	24.7	5.9			
	4	24.7	5.5			
	5	24.7	6.4			
69.5/30.5	1	30.5	4.0	3.6	0.4	11.3
	2	30.5	4.0			
	3	30.5	3.6			
	4	30.5	3.1			
	5	30.5	3.2			
60.3/39.7	1	39.7	3.1	3.2	0.3	8.0
	2	39.7	3.4			
	3	39.7	3.5			
	4	39.7	2.9			
	5	39.7	3.4			
100% CF ₃ I	NMERI Value	100.0	3.2	3.2		

TABLE 11. CUP-BURNER DATA FOR CF₃I AND HFC-134a BLENDS.

Blend HFC-134a/CF ₃ I, %	Test No.	Wt. % CF ₃ I	Ext. Conc., Vol. %	Ave Ext. Conc., Vol %	Standard Deviation	% Error
100% HFC-134a	NMERI Value	0	10.5	10.5		
100% HFC-134a	1	0.0	10.0	10.9	0.6	5.7
	2	0.0	11.2			
	3	0.0	11.1			
	4	0.0	11.5			
88.6/11.4	1	11.4	8.6	9.2	0.5	5.8
	2	11.4	8.8			
	3	11.4	9.9			
	4	11.4	9.3			
	5	11.4	9.6			
84.2/15.8	1	15.8	7.2	7.8	0.5	6.7
	2	15.8	7.4			
	3	15.8	7.8			
	4	15.8	8.5			
	5	15.8	8.0			
78.9/21.1	1	21.1	6.1	6.1	0.2	3.6
	2	21.1	6.3			
	3	21.1	6.2			
	4	21.1	6.0			
	5	21.1	5.8			
75.5/24.5	1	24.5	6.1	6.1	0.2	4.1
	2	24.5	5.7			
	3	24.5	6.4			
	4	24.5	6.1			
	5	24.5	5.9			
68.5/31.5	1	31.5	5.0	5.2	0.2	4.3
	2	31.5	4.9			
	3	31.5	5.4			
	4	31.5	5.4			
	5	31.5	5.2			
	6	31.5	5.9	6.6	0.6	8.4
	7	31.5	6.1			

TABLE 11. CUP-BURNER DATA FOR CF₃I AND HFC-134a BLENDS (CONCLUDED).

Blend HFC-134a/CF ₃ I, %	Test No.	Wt. % CF ₃ I	Ext. Conc., Vol. %	Ave Ext. Conc., Vol %	Standard Deviation	% Error
60.4/39.6	8	31.5	6.5	3.7	0.3	7.0
	9	31.5	7.0			
	10	31.5	7.1			
	11	31.5	7.2			
	1	39.6	3.8			
	2	39.6	3.8			
	3	39.6	4.0			
	4	39.6	3.4			
	5	39.6	3.5			
	NMERI	100.0	3.2			
	Value					
100% CF ₃ I				3.2		

Figure 5 and Table 12 show the cup-burner results for CF₃I blended with HFC-227ea using the revised cup-burner test setup and the classical setup. The one classical test method value that is shown in Figure 5 is much higher than those determined using the revised method. Also, the extinguishment concentrations for the 20 percent through 80 percent CF₃I blends are less than the extinguishment concentration for 100 percent CF₃I. An explanation for this has not been determined at this time.

Figure 6 and Table 13 show the revised cup-burner test results for CF₃I blended with HFC-236fa. An exponential curve fit to the Tyndall ARA data is also shown. The data in Figure 6 show significant scatter, which is not typical of that observed for other compounds tested. This scatter has been attributed to possible composition change as agent was expelled. Also, Tyndall and NMERI results differ. In Figure 7, the average cup-burner results for the CF₃I and HFC-236fa blends are shown, along with the classical method results and an exponential fit to the Tyndall data. The classical test method data and the Tyndall data are in close agreement, as shown by the exponential fit to both the Tyndall and NMERI classical method data (Figure 7); however, the extinguishment concentrations are higher than for the revised method.




Figure 5. Cup-Burner Extinguishment Concentrations for CF₃I and HFC-227ea Blends.

TABLE 12. CUP-BURNER DATA FOR CF₃I AND HFC-227ea BLENDS.

Blend HFC-227ea/CF ₃ I, %	Ext. Conc., Vol. %	Avg. Ext. Conc., Vol. %	Average Deviation	% Deviation
100% HFC-227ea	4.9	5.1	0.6	11.7
	4.9			
	5.5			
96.8/3.2	4.2	5.6	0.8	14.7
	5.7			
	6.1			
	6.2			
	5.8			
92.4/7.6	5.0	4.4	0.4	8.4
	4.4			
	4.4			
	4.0			
	4.5			
89.2/10.8	3.1	3.0	0.2	6.6
	2.8			
	3.0			
	2.8			
	3.3			
80.2/19.8	1.8	2.4	0.4	17.5
	2.5			
	3.0			
	2.4			
	2.2			
77.5/22.5	5.1	4.5	0.4	8.6
	4.2			
	4.6			
	4.5			
	4.2			
60.5/39.5	1.9	1.7	0.4	22.2
	1.9			
	2.1			
	1.1			
	1.6			
44.8/55.2	1.9	1.1	0.4	39.4
	0.9			
	0.8			
	1.0			
	1.2			
20.5/79.5	1.4	1.6	0.5	31.4
	2.4			
	1.1			
	1.4			
	1.6			
100% CF ₃ I	3.2	3.2	---	---

TABLE 13. CUP-BURNER DATA FOR CF₃I AND HFC-236fa BLENDS.

Blend HFC-236fa/CF ₃ I, %	Ext. Conc., Vol. %	Avg. Ext. Conc., Vol. %	Average Deviation	% Deviation
100% HFC-236fa	5.6	5.6	---	---
97.7/2.3	5.1	4.7	0.5	9.7
	5.1			
	4.5			
	4.7			
	4.0			
95.7/4.3	4.0	4.7	0.4	9.1
	5.2			
	4.4			
	4.4			
	4.7			
	4.9			
	5.1			
93.6/6.4	4.9	5.7	0.6	10.9
	5.7			
	5.3			
	6.4			
	6.5			
	5.5			
93.4/6.6	3.7	3.7	0.4	9.8
	4.1			
	3.5			
	3.2			
	3.9			
	3.2			
	3.9			
91.4/8.6	3.9	3.1	0.7	22.1
	3.3			
	2.9			
	2.1			
	3.2			

TABLE 13. CUP-BURNER DATA FOR CF₃I AND HFC-236fa BLENDS (CONTINUED).

Blend HFC-236fa/CF ₃ I, %	Ext. Conc., Vol. %	Avg. Ext. Conc., Vol. %	Average Deviation	% Deviation
90.4/9.6	4.5	5.0	1.0	20.9
	4.0			
	3.8			
	5.6			
	5.6			
	6.5			
86.8/13.2	2.6	2.6	0.31	11.9
	3.0			
	2.2			
	2.6			
	2.7			
86.5/13.5	4.1	4.9	0.5	10.1
	4.5			
	4.8			
	5.0			
	5.2			
	5.6			
83.3/16.7	5.1	5.0	0.2	3.8
	4.9			
	5.2			
	4.8			
	5.2			
80/20	4.9	3.3	0.3	9.0
	3.3			
	2.9			
	3.3			
	3.7			
	3.5			
76.9/23.1	3.6	3.9	0.1	3.8
	3.7			
	3.9			
	3.9			
	3.8			
	3.7			
	4.1			

TABLE 13. CUP-BURNER DATA FOR CF₃I AND HFC-236fa BLENDS (CONCLUDED).

Blend HFC-236fa/CF ₃ I, %	Ext. Conc., Vol. %	Avg. Ext. Conc., Vol. %	Average Deviation	% Deviation
74.2/25.8 (Series 1)	4.3	3.5	0.6	17.7
	3.9			
	3.4			
	2.9			
	2.9			
74.2/25.8 (Series 2)	4.5	6.3	1.4	21.9
	7.2			
	6.2			
	7.6			
68.9/31.1	4.5	4.2	0.2	5.4
	4.1			
	3.9			
	4.2			
	4.4			
58.5/41.5	4.2	3.8	0.2	4.6
	3.9			
	4.0			
	3.8			
	3.5			
56.4/43.5	3.7	3.3	0.4	12.2
	3.3			
	3.8			
	2.8			
	3.4			
100% CF ₃ I	3.2	3.2	---	---




Figure 6. Cup-Burner Extinction Concentrations for CF₃I and HFC-236fa Blends.




Figure 7. Average Cup-Burner Extinction Concentrations for CF₃I and HFC-236fa Blends.

C. DISCUSSION

As shown in Figures 6 and 7 there are differences between the extinguishment concentrations when using the classical and the revised methods as the weight percentage of CF_3I increases. This difference could be due to separation or inadequate mixing of the CF_3I and the HFC compound in the small discharge cylinder (Figure 2). If the denser component, CF_3I , is discharged through the cup burner first, followed by the HFC, it would be expected that the extinguishment concentration of a blend would increase as more and more of the blend is discharged from the cylinder.

Three experiments were performed with the goal of explaining the difference between the extinguishment concentrations when using the two methods. The first experiment entailed investigating the extinguishment concentration values for each cup-burner extinguishment series. In the cup-burner extinguishment series, five tests are performed to determine the average concentration value for the blend. Typically, 100 grams total of the blend were loaded into the discharge cylinder; however, 50 to 70 grams were used during the five tests. If CF_3I is being discharged first, due to its being on the bottom of the discharge cylinder, then the measured extinguishment concentration will increase as more agent is discharged from the cylinder. The first extinguishment test for each blend would have a lower concentration value than the last extinguishment test. The results from the cup-burner testing of the CF_3I blends are shown in Tables 11 - 13. The data presented in these tables do not show any increasing trend, indicating that no separation is taking place (Table 14).

Figure 7 and Table 13 show the results of a second experiment that was performed to investigate the possibility of CF_3I separation. In this experiment, five extinguishment tests were performed with the 25.8 percent CF_3I and 74.2 percent HFC-236fa blend (Table 13). At the end of the first five tests, the discharge cylinder was shaken and another series of five tests was performed. The extinguishing concentration shown in Figure 7 for the second half of the discharge cylinder is higher than the first half of the cylinder, which indicates that separation of CF_3I in the blend could be occurring.

TABLE 14. SELECTED DATA FOR 68.9 PERCENT HFC-236fa AND
31.1 PERCENT CF₃I BLEND.

Test No.	Ext. Conc., Vol %	Weight Used During Test, g
1	4.4	18.0
2	4.0	5.7
3	3.8	6.3
4	4.0	10.3
5	4.2	13.1
6	4.1	12.0
Average = 4.1		Total = 65.4

^aInitial blend weight in cylinder was 144 g total with 44.7 g CF₃I.

^bThe total weight discharged exceeded the amount of CF₃I in the blend.

A third experiment was performed. In this experiment, a Fourier Transform Infrared (FTIR) spectrometer was used to observe the CF₃I and HFC-236fa peaks throughout a series of cup-burner tests. In the FTIR experiment, the cup-burner discharge cylinder was filled with the CF₃I and HFC blend and the standard cup-burner extinguishment experiment was performed. Just prior to and right after the agent blend extinguished the cup-burner flame, several scans were taken with the FTIR. The peak heights and ratios between the CF₃I and HFC peaks are shown in Tables 15 and 16. Six example FTIR spectra are shown in Figures 8 - 13. The ratios between the CF₃I and HFC-227ea peaks in Table 15 indicate that the composition of the blended agents in the blend remained the same throughout the discharge, indicating that separation of CF₃I was not occurring. The same appears to be true for Blend Tests 4, 5, 6, 7, 8, and 10 for HFC-236fa (Table 16). Slight differences did occur between the ratios of the second peaks on Table 16; however, as shown in Figures 10 - 13, the second CF₃I peak is slightly influenced by a HFC-236fa peak. Additional investigations of this phenomena are ongoing.

TABLE 15. FTIR EXPERIMENTAL TEST RESULTS: CF₃I AND HFC-227ea BLENDS.

Name	CF ₃ I	HFC-227ea	HFC-227ea	Ratio of CF ₃ I to HFC-227ea	
	Peak 1	Peak 1	Peak 2	Peak 1	Peak 2
BLEND TEST #1: 21.2% CF ₃ I and 78.8% HFC-227ea					
BLEND1B.SP	0.100	0.187	0.123	0.53	0.81
BLEND1C.SP	0.182	0.335	0.220	0.54	0.83
BLEND1D.SP	0.010	0.021	0.015	0.48	0.67
BLEND1E.SP	0.014	0.025	0.019	0.56	0.74
BLEND1F.SP	0.224	0.415	0.274	0.54	0.82
BLEND1G.SP	0.202	0.377	0.249	0.54	0.81
BLEND1H.SP	0.013	0.023	0.016	0.57	0.81
BLEND1I.SP	0.146	0.276	0.183	0.53	0.80
BLEND1J.SP	0.011	0.022	0.016	0.50	0.69
BLEND1K.SP	0.092	0.180	0.118	0.51	0.78
BLEND1L.SP	0.236	0.435	0.287	0.54	0.82
BLEND1M.SP	0.009	0.018	0.013	0.50	0.69
BLEND1N.SP	0.095	0.166	0.110	0.57	0.86
BLEND1O.SP	0.163	0.300	0.198	0.54	0.82
BLEND1P.SP	0.181	0.333	0.222	0.54	0.82
BLEND TEST #2: 23.1% CF ₃ I and 76.9% HFC-227ea					
BLEND2A.SP	0.073	0.122	0.079	0.60	0.92
BLEND2B.SP	0.155	0.259	0.170	0.60	0.91
BLEND2C.SP	0.257	0.460	0.301	0.56	0.85
BLEND2D.SP	0.213	0.385	0.255	0.55	0.84
BLEND2E.SP	0.233	0.408	0.268	0.57	0.87
BLEND2F.SP	0.206	0.372	0.247	0.55	0.83
BLEND2H.SP	0.099	0.169	0.107	0.59	0.93
BLEND2K.SP	0.168	0.295	0.193	0.57	0.87
BLEND2L.SP	0.188	0.333	0.218	0.56	0.86
BLEND2M.SP	0.557	0.934	0.624	0.60	0.89
BLEND2N.SP	1.218	2.661	1.463	0.46	0.83

TABLE 16. FTIR EXPERIMENTAL TEST RESULTS: CF₃I AND HFC-236fa BLENDS.

Name	CF ₃ I Peaks		HFC-236fa Peaks		Ratio of CF ₃ I to HFC-236fa			
	1a	2a	1b	2b	1a/1b	1a/2b	2a/1b	2a/2b
BLEND4A.SP	0.046	0.033	0.166	0.180	0.28	0.26	0.20	0.18
BLEND4B.SP	0.031	0.024	0.102	0.115	0.30	0.27	0.24	0.21
BLEND4C.SP	0.029	0.024	0.098	0.105	0.30	0.28	0.24	0.23
BLEND4D.SP	0.029	0.025	0.100	0.109	0.29	0.27	0.25	0.23
BLEND4E.SP	0.036	0.022	0.069	0.081	0.52	0.44	0.32	0.27
BLEND4F.SP	0.033	0.029	0.123	0.135	0.27	0.24	0.24	0.21
BLEND4G.SP	0.031	0.022	0.064	0.093	0.48	0.33	0.34	0.24
BLEND4H.SP	0.031	0.022	0.064	0.134	0.48	0.23	0.34	0.16
Average =					0.37	0.29	0.27	0.22
Std. Dev. =					0.11	0.07	0.06	0.03
BLEND5A.SP	0.035	1.314	0.128	0.347	0.27	0.10	10.27	3.79
BLEND5B.SP	0.043	1.031	0.104	0.344	0.41	0.13	9.91	3.00
BLEND5C.SP	0.077	0.904	0.358	0.473	0.22	0.16	2.53	1.91
BLEND5D.SP	0.039	0.674	0.182	0.268	0.21	0.15	3.70	2.51
BLEND5E.SP	0.087	0.630	0.344	0.392	0.25	0.22	1.83	1.61
BLEND5F.SP	0.074	0.585	0.286	0.330	0.26	0.22	2.05	1.77
BLEND5G.SP	0.115	0.539	0.428	0.478	0.27	0.24	1.26	1.13
BLEND5H.SP	0.032	0.402	0.154	0.266	0.21	0.12	2.61	1.51
Average =					0.26	0.17	4.27	2.15
Std. Dev. =					0.07	0.05	3.66	0.88
BLEND6A.SP	0.027	0.434	0.129	0.355	0.21	0.08	3.36	1.22
BLEND6B.SP	0.025	0.387	0.060	0.293	0.42	0.09	6.45	1.32
BLEND6C.SP	0.085	0.451	0.319	0.447	0.27	0.19	1.41	1.01
BLEND6D.SP	0.045	0.425	0.158	0.182	0.28	0.25	2.69	2.34
BLEND6E.SP	0.061	0.441	0.208	0.238	0.29	0.26	2.12	1.85
BLEND6F.SP	0.044	0.427	0.153	0.178	0.29	0.25	2.79	2.40
BLEND6G.SP	0.100	0.473	0.324	0.362	0.31	0.28	1.46	1.31
BLEND6H.SP	0.141	0.498	0.450	0.509	0.31	0.28	1.11	0.98
Average =					0.30	0.21	2.67	1.55
Std. Dev. =					0.06	0.08	1.71	0.57

TABLE 16. FTIR EXPERIMENTAL TEST RESULTS: CF₃I AND HFC-236fa
BLENDS (CONTINUED).

Name	CF ₃ I Peaks		HFC-236fa Peaks		Ratio of CF ₃ I to HFC-236fa			
	1a	2a	1b	2b	1a/1b	1a/2b	2a/1b	2a/2b
BLEND7A.SP	0.002	0.176	0.008	0.101	0.25	0.02	22.00	1.74
BLEND7B.SP	0.150	0.290	0.494	0.651	0.30	0.23	0.59	0.45
BLEND7C.SP	0.129	0.280	0.431	0.500	0.30	0.26	0.65	0.56
BLEND7D.SP	0.063	0.220	0.198	0.234	0.32	0.27	1.11	0.94
BLEND7E.SP	0.131	0.254	0.425	0.492	0.31	0.27	0.60	0.52
BLEND7F.SP	0.051	0.192	0.178	0.208	0.29	0.25	1.08	0.92
BLEND7G.SP	0.230	0.305	0.742	0.829	0.31	0.28	0.41	0.37
BLEND7H.SP	0.127	0.225	0.399	0.462	0.32	0.27	0.56	0.49
Average =					0.30	0.23	3.37	0.75
Std. Dev. =					0.02	0.09	7.53	0.46
BLEND8A.SP	0.399	0.931	0.700	---	0.57	---	1.33	---
BLEND8B.SP	0.162	0.318	0.256	---	0.63	---	1.24	---
BLEND8C.SP	0.127	0.230	0.198	---	0.64	---	1.16	---
BLEND8D.SP	0.239	0.288	0.370	---	0.65	---	0.78	---
BLEND8E.SP	0.155	0.172	0.246	---	0.63	---	0.70	---
BLEND8F.SP	0.109	0.126	0.174	---	0.63	---	0.72	---
BLEND8G.SP	0.081	0.105	0.134	---	0.60	---	0.78	---
BLEND8H.SP	0.064	0.098	0.114	---	0.56	---	0.86	---
Average =					0.61	---	0.95	---
Std. Dev. =					0.03	---	0.25	---
BLEND9A.SP	0.063	0.662	0.248	---	0.25	---	2.67	---
BLEND9B.SP	0.131	0.686	0.352	---	0.37	---	1.95	---
BLEND9C.SP	0.233	0.725	0.445	---	0.52	---	1.63	---
BLEND9D.SP	0.228	0.680	0.418	---	0.55	---	1.63	---
BLEND9E.SP	0.098	0.219	0.187	---	0.52	---	1.17	---
BLEND9F.SP	0.237	0.290	0.419	---	0.57	---	0.69	---
BLEND9G.SP	0.146	0.220	0.276	---	0.53	---	0.80	---
BLEND9H.SP	0.113	0.197	0.220	---	0.51	---	0.90	---
Average =					0.48	---	1.43	---
Std. Dev. =					0.11	---	0.67	---

TABLE 16. FTIR EXPERIMENTAL TEST RESULTS: CF₃I AND HFC-236fa
BLENDS (CONCLUDED).

Name	CF ₃ I Peaks		HFC-236fa Peaks		Ratio of CF ₃ I to HFC-236fa			
	1a	2a	1b	2b	1a/1b	1a/2b	2a/1b	2a/2b
BLEND10A.SP	0.344	1.137	0.567	0.691	0.61	0.50	2.01	1.65
BLEND10B.SP	0.275	0.488	0.453	0.544	0.61	0.51	1.08	0.90
BLEND10C.SP	0.199	0.360	0.333	0.400	0.60	0.50	1.08	0.90
BLEND10D.SP	0.175	0.344	0.277	0.318	0.63	0.55	1.24	1.08
BLEND10E.SP	0.155	0.280	0.250	0.297	0.62	0.52	1.12	0.94
BLEND10F.SP	0.133	0.233	0.219	0.274	0.61	0.49	1.06	0.85
BLEND10G.SP	0.314	0.306	0.499	0.577	0.63	0.54	0.61	0.53
BLEND10H.SP	0.215	0.222	0.363	0.432	0.59	0.50	0.61	0.51
Average =					0.61	0.51	1.10	0.92
Std. Dev. =					0.01	0.02	0.43	0.35




Figure 8. Blend Test #1: 21.2% CF₃I and 78.8% HFC-227ea Scan at Start of Test.




Figure 9. Blend Test #1: 21.2% CF₃I and 78.8% HFC-227ea Scan Toward End of Test.




Figure 10. Blend Test #2: 23.1% CF₃I and 76.9% HFC-236fa Scan at Start of Test.




Figure 11. Blend Test #2: 23.1% CF₃I and 76.9% HFC-236fa Scan Toward End of Test.




Figure 12. Blend Test #5: 41.5% CF₃I and 58.5% HFC-236fa Scan at Start of Test.




Figure 13. Blend Test #5: 41.5% CF₃I and 58.5% HFC-236fa Scan Toward End of Test.

D. SUMMARY

Figure 14 shows a summary of the CF_3I and HFC blend cup-burner extinguishment concentrations. The Tyndall ARA data are also shown. The CF_3I and HFC-227ea and -236fa blends, as shown, proved to be the most effective of the HFCs tested. The revised cup-burner method results indicate that a 20 to 40 percent by weight blend of CF_3I and HFC-236fa would have a slight decrease in extinguishing performance versus 100 percent CF_3I . Based on the cup-burner test results, it is recommended that laboratory and medium scale testing of CF_3I blends with HFC-227ea and HFC-236fa be performed. Limited testing with either HFC-134a or HFC-125 may also be warranted. These agents, however, have low boiling points and are likely to be inadequate as streaming agents.




Figure 14. Summary of Cup-Burner Extinguishment Concentrations for HFC and CF_3I Blends.

SECTION V

CONCLUSIONS AND RECOMMENDATIONS

A. CONCLUSIONS

Seven HFC agents (HFC-23, -125, -134a, -143a, -227ea, -236fa, and -4-3-10mee) have been identified that meet toxicity, regulatory, and availability requirements for inclusion as blending agents with CF₃I. For five of the compounds that are widely available and have known cardiac sensitization NOAEL values, no more than 40 percent CF₃I may be contained in a blend in order to match the cardiac sensitization NOAEL value of Halon 1211. Fire suppression effectiveness testing using the cup-burner method indicates that the extinguishing concentrations of four 40 percent blends range from slightly higher than that of CF₃I to significantly lower. Analysis of FTIR scans at different times shows no fractionation of agents during discharge. CF₃I blends with HFC-227ea and HFC-236fa are the most likely to meet USAF streaming agent requirements.

B. RECOMMENDATIONS

Those agents identified as meeting the criteria for continuation in the program should be tested in laboratory- and field-scale streaming apparatuses. Toxicity assessments of one or more blends identified in this program should be conducted.

REFERENCES

1. Moore, T. A., Skaggs, S. R., Corbitt, M. R., Tapscott, R. E., Dierdorf, D. S., And Kibert, C. J., *The Development of CF3I as a Halon Replacement*, WL-TR-94-XX, Wright Laboratories, Infrastructure Technology Section, Tyndall AFB, Florida, November 1994.
2. Clark, D. G. and Tinston, D. J., "Acute Inhalation Toxicity of some Halogenated and Non-Halogenated Hydrocarbons," *Human Toxicology*, Vol. 1, pp. 239-247, 1982.
3. Graham, R. C., *Toxicity Summary for Bromochlorodifluoromethane*, DuPont Haskell Laboratory, Newark, Delaware, Update, April 11, 1983.
4. ManTech Environmental Technologies, *Acute Inhalation Toxicity Study of Iodotrifluoromethane in Rats*, Study No. 2, Project No. 1530-001, March 1994.
5. Beck, P. S., Clark, D. G., and Tinston, D. J., "The Pharmacologic Actions of Bromochlorodifluoromethane (BCF)," *Toxicology and applied Physiology*, Vol. 24, pp. 20-29, 1973.
6. "ManTech Environmental Technologies," *Acute Inhalation Toxicity Study of Iodotrifluoromethane in Rats*, Study No. 1, Project No. 6030-012, August 1993.
7. Shepherd, K. T., Shepherd, C., and Hardy, C., *Iodotrifluoromethane and Iodoheptafluoropropane, Assessment of Cardiac Sensitization Potential in Dogs*, AL/OE-TR-1995-0031, Armstrong Laboratory, Wright-Patterson AFB, Ohio, February 1995.
8. American Conference of Governmental Industrial Hygienists, *TLVs: Threshold Limit Values for Chemical Substances and Physical Agents in the Workroom Environment with Intended Changes for 1977*, American Conference of Governmental Industrial Hygienists, Cincinnati, Ohio, p. 94, 1977.
9. *NFPA 2001 Standard on Clean Agent Fire Extinguishing Systems*, 1994 Edition, National Fire Protection Association, Quincy, Massachusetts, 1994.
10. "Halon 13B1, Freon 23," *Mixture of Freon 23 and HFC 125, Assessment of Cardiac Sensitization Potential in Dogs*, DPT 273/921009, Huntingdon Research Centre Ltd., Huntingdon, Cambridgeshire, England, Haskell Laboratory for Toxicology and Industrial Medicine, Newark, Delaware, March 15, 1993.
11. Reinhardt, C. F., Azar, A., Maxfield, M. E., Smith, P. E., and Mullin, L. S., "Cardiac Arrhythmias and Aerosol 'Sniffing'," *Archives of Environmental Health*, Vol. 22, pp. 265-279, February 1971.
12. "RIVM Study Assesses HFC Policy Options and Effects," *Global Environmental Change Report*, Vol. 7, No. 2, p. 4, January 27, 1995.

13. *Montreal Protocol on Substances that Deplete the Ozone Layer, Report of the Halon Fire Extinguishing Agents Technical Options Committee*, United Nations Environment Programme, Paris, France, pp. 1-2, December 1994.
14. Klink, F. W., Minday, R. M., Owens, J. G., and Flynn, R. M., "New Fluorinated Alternatives to Ozone Depleting Substances," International CFC and Halon Alternatives Conference, Washington, DC, October 24-26, 1994.
15. Grenvell, M. W., Klink, F. W., Owens, J. G., and Yanome, H., "New Fluorinated Solvent Alternatives," Precision Cleaning '95, Rosemont, Illinois, May 15-17, 1995.
16. Merchant, A. N., "An Update on HFC-43-10mee," 1994 International CFC and Halon Alternatives Conference, Washington, DC, October 24-26, 1994.
17. Basu, R. S., "Cleaning and Drying Using Hydrofluorocarbon Solvents," 1994 International CFC and Halon Alternatives Conference, Washington, DC, October 24-26, 1994.
18. "AlliedSignal and 3M Form Solvents Alliance," *Chemical Week*, Vol. 156, No. 21, p. 8, May 31, 1995.
19. *Federal Register*, Vol. 59, No. 53, pp. 13044-13161, March 18, 1994.
20. *Risk Screen on the Use of Substitutes for Class I Ozone-Depleting Substances: Fire Suppression and Explosion Protection (Halon Substitutes)*, SNAP Technical Background Document, U.S. Environmental Protection Agency, Office of Air and Radiation, Stratospheric Protection Division, Washington, DC, March 1994.
21. *Federal Register*, Vol. 59, No. 165, pp. 44240-44256, August 26, 1994.
22. *Federal Register*, Vol. 59, No. 185, pp. 49108-49121, September 26, 1994.
23. *Federal Register*, Vol. 60, No. 9, pp. 3318-3322, January 13, 1995.
24. *Federal Register*, Vol. 60, No. 113, pp. 31092-31107, June 13, 1995.
25. *Federal Register*, Vol. 60, No. 145, pp. 38729-38731, July 28, 1995.
26. Moore, D. W., "FE 36 Fire Extinguishing Agent," DuPont Product Literature, June 7, 1994.
27. Tapscott, R. E., May, J. H., Moore, J. P., Lee, M. E., and Walker, J. L., *Next Generation Fire Extinguishing Agents Phase II — Laboratory Tests and Scoping Trials*, ESL-TR-87-03, Vol. 2 of 5, Air Force Engineering and Services Laboratory, Tyndall AFB, Florida, April 1990.

WL-TR-95-XX

FLUOROIODIDE BLENDS AS STREAMING AGENTS:
SELECTION CRITERIA AND CUP-BURNER RESULTS

Robert E. Tapscott, Ted A. Moore, Stephanie R. Skaggs, and Everett W. Heinonen

NEW MEXICO ENGINEERING RESEARCH INSTITUTE
The University of New Mexico
Albuquerque, New Mexico 87131-1376

Final Report for Period October 1994 through December 1994

June 1995

Prepared for:

WRIGHT LABORATORIES (WL/FIVCF)
139 Barnes Drive, Suite 2
Infrastructure Technology Section
Tyndall Air Force Base, Florida 32403-5323

and

APPLIED RESEARCH ASSOCIATES, INC.
P.O. Box 40128
Tyndall Air Force Base, Florida 32403-5323